



Harmonic Analysis


Sample Analysis - 30kva Xfmr, 600 - 120/208, delta-wye, K=1



Measured Values				
Phase C				
		Voltage	Current	
Frequency	60	RMS	118	69
Power		Peak	161.9	145.9
KW	7.2	DC Offset	-0.4	0.2
KVA	8.1	Crest	1.37	2.11
KVAR	0.5	THD Rms	4.1	45
Peak KW	23.7	THD Fund	4.1	50.3
Phase	4° lag	HRMS	4.8	31
Total PF	0.89	KFactor		4
DPF	1			




Harmonic Values					
		Voltage		Current	
Harmonic	Magnitude	% of fund.	Magnitude	% of fund.	
DC	0.4	0.4	0.2	0.3	
1	117.9	99.9	61.6	89.3	
2	0.0	0.0	0.3	0.4	
3	2.1	1.8	27.0	39.1	
4	0.0	0.0	0.1	0.2	
5	3.2	2.7	14.0	20.2	
6	0.0	0.0	0.1	0.1	
7	2.4	2.0	4.5	6.5	
8	0.0	0.0	0.0	0.0	
9	0.6	0.5	3.0	4.3	
10	0.0	0.0	0.0	0.0	
11	1.1	0.9	2.3	3.3	
12	0.0	0.0	0.0	0.0	
13	0.7	0.6	1.2	1.8	
14	0.0	0.0	0.0	0.0	
15	0.4	0.4	1.2	1.7	
16	0.0	0.0	0.0	0.0	
17	0.5	0.5	0.8	1.1	
18	0.0	0.0	0.0	0.0	
19	0.4	0.4	0.6	0.9	
20	0.0	0.0	0.0	0.0	
21	0.3	0.3	0.6	0.8	
22	0.0	0.0	0.0	0.0	
23	0.3	0.3	0.4	0.5	
24	0.0	0.0	0.0	0.0	
25	0.3	0.3	0.4	0.6	
26	0.0	0.0	0.0	0.0	
27	0.3	0.2	0.3	0.4	
28	0.0	0.0	0.0	0.0	
29	0.2	0.2	0.2	0.3	
30	0.0	0.0	0.0	0.0	
31	0.3	0.2	0.3	0.5	




Harmonic Analysis


Sample Analysis - 30kva Xfmr, 600 - 120/208, delta-wye, K=1




Measured Values				
Phase B				
		Voltage	Current	
Frequency	60	RMS	114.6	86
Power		Peak	156	182
KW	8.7	DC Offset	-0.4	-3
KVA	9.9	Crest	1.36	2.11
KVAR	1.2	THD Rms	4.9	45.5
Peak KW	29	THD Fund	5	51.1
Phase	8° lag	HRMS	5.7	39
Total PF	0.88	KFactor		4.2
DPF	0.99			




Harmonic Values				
Harmonic	Voltage		Current	
	Magnitude	% of fund.	Magnitude	% of fund.
DC	0.4	0.4	3.0	3.2
1	114.5	99.9	77.0	89.0
2	0.1	0.1	0.0	0.4
3	3.2	2.8	34.0	39.2
4	0.0	0.0	0.0	0.4
5	3.4	2.9	18.0	21.2
6	0.0	0.0	0.0	0.4
7	2.4	2.1	6.0	6.5
8	0.0	0.0	0.0	0.4
9	0.9	0.8	4.0	4.6
10	0.0	0.0	0.0	0.1
11	1.2	1.1	3.0	3.4
12	0.0	0.0	0.0	0.1
13	0.7	0.6	2.0	2.2
14	0.0	0.0	0.0	0.2
15	0.5	0.5	2.0	1.9
16	0.0	0.0	0.0	0.2
17	0.6	0.5	1.0	1.2
18	0.0	0.0	0.0	0.1
19	0.6	0.5	1.0	1.3
20	0.0	0.0	0.0	0.0
21	0.4	0.3	1.0	0.9
22	0.0	0.0	0.0	0.1
23	0.4	0.3	1.0	0.7
24	0.0	0.0	0.0	0.1
25	0.5	0.4	1.0	0.7
26	0.0	0.0	0.0	0.1
27	0.3	0.2	0.0	0.5
28	0.0	0.0	0.0	0.1
29	0.3	0.3	0.0	0.4
30	0.0	0.0	0.0	0.0
31	0.3	0.2	0.0	0.4




Sample Analysis - 30kva Xfmr, 600 - 120/208, delta-wye, K=1



Measured Values				
Phase A				
		Voltage	Current	
Frequency	60	RMS	118.5	70.6
Power		Peak	162	156.8
KW	6.9	DC Offset	-0.4	-0.2
KVA	8.4	Crest	1.37	2.22
KVAR	1.4	THD Rms	4.9	53.4
Peak KW	25.5	THD Fund	4.9	63.1
Phase	11° lag	HRMS	5.8	37.7
Total PF	0.83	KFactor		5.7
DPF	0.98			




Harmonic Values				
	Voltage		Current	
Harmonic	Magnitude	% of fund.	Magnitude	% of fund.
DC	0.4	0.3	0.2	0.3
1	118.4	99.9	59.7	84.6
2	0.0	0.0	0.0	0.0
3	2.5	2.1	32.1	45.5
4	0.0	0.0	0.0	0.0
5	3.6	3.1	17.8	25.1
6	0.0	0.0	0.0	0.0
7	2.7	2.3	6.0	8.5
8	0.0	0.0	0.0	0.0
9	1.1	0.9	4.0	5.6
10	0.0	0.0	0.0	0.0
11	1.3	1.1	3.0	4.2
12	0.0	0.0	0.0	0.0
13	0.9	0.7	1.9	2.7
14	0.0	0.0	0.0	0.0
15	0.8	0.7	1.8	2.5
16	0.0	0.0	0.0	0.0
17	0.6	0.5	1.0	1.5
18	0.0	0.0	0.0	0.0
19	0.7	0.6	1.1	1.6
20	0.0	0.0	0.0	0.0
21	0.6	0.5	1.0	1.4
22	0.0	0.0	0.0	0.0
23	0.4	0.3	0.6	0.9
24	0.0	0.0	0.0	0.0
25	0.6	0.5	0.8	1.1
26	0.0	0.0	0.0	0.0
27	0.4	0.4	0.6	0.8
28	0.0	0.0	0.0	0.0
29	0.4	0.3	0.5	0.7
30	0.0	0.0	0.0	0.0
31	0.4	0.3	0.5	0.7




Harmonic Analysis

Sample Analysis - 30kva Xfmr, 600 - 120/208, delta-wye, K=1




Measured Values	
Neutral	
	Current
RMS	59.3
Peak	93.4
DC Offset	-0.3
Crest	1.57
THD Rms	93.5
THD Fund	264.7
HRMS	55.5




Harmonic Values		
	Current	
Harmonic	Magnitude	% of fund.
DC	0.3	0.5
1	21.0	35.3
2	0.3	0.4
3	55.4	93.4
4	0.1	0.2
5	1.5	2.5
6	0.1	0.1
7	0.6	1.1
8	0.0	0.1
9	2.3	3.8
10	0.1	0.1
11	0.5	0.9
12	0.0	0.0
13	0.4	0.7
14	0.0	0.0
15	1.1	1.8
16	0.0	0.1
17	0.2	0.3
18	0.0	0.0
19	0.1	0.2
20	0.0	0.0
21	0.2	0.3
22	0.0	0.0
23	0.0	0.1
24	0.0	0.0
25	0.0	0.0
26	0.0	0.0
27	0.0	0.0
28	0.0	0.0
29	0.0	0.0
30	0.0	0.0
31	0.0	0.1

Harmonic Analysis


Sample Analysis - 30kva Xfmr, 600 - 120/208, delta-wye, K=1



Measured Values				
Input Line 1				
		Voltage		Current
Frequency	60	RMS	591	27.4
Power		Peak	825	41.2
KW	11.2	DC Offset	-2	-0.2
KVA	16.2	Crest	1.4	1.5
KVAR	11.1	THD Rms	2.1	23.6
Peak KW	33.7	THD Fund	2.1	24.2
Phase	45° lag	HRMS	13	6.5
Total PF	0.69	KFactor		2.8
DPF	0.71			




Harmonic Values					
		Voltage		Current	
Harmonic	Magnitude	% of fund.	Magnitude	% of fund.	
DC	2.0	0.3	0.2	0.8	
1	590.0	100.0	26.6	97.2	
2	0.0	0.1	0.0	0.1	
3	2.0	0.4	0.7	2.4	
4	0.0	0.0	0.0	0.1	
5	9.0	1.5	6.0	21.9	
6	0.0	0.0	0.0	0.1	
7	0.0	0.0	2.0	7.2	
8	0.0	0.0	0.0	0.1	
9	1.0	0.1	0.0	0.1	
10	0.0	0.0	0.0	0.1	
11	3.0	0.5	0.9	3.3	
12	0.0	0.0	0.0	0.1	
13	1.0	0.2	0.6	2.3	
14	0.0	0.0	0.1	0.2	
15	0.0	0.1	0.1	0.2	
16	0.0	0.0	0.0	0.1	
17	2.0	0.3	0.3	1.2	
18	0.0	0.0	0.0	0.1	
19	1.0	0.1	0.4	1.3	
20	0.0	0.0	0.0	0.1	
21	0.0	0.0	0.0	0.0	
22	0.0	0.0	0.0	0.1	
23	1.0	0.2	0.2	0.8	
24	0.0	0.0	0.0	0.1	
25	0.0	0.1	0.2	0.8	
26	0.0	0.0	0.0	0.0	
27	0.0	0.0	0.0	0.0	
28	0.0	0.0	0.0	0.1	
29	0.0	0.0	0.1	0.5	
30	0.0	0.0	0.0	0.0	
31	0.0	0.0	0.1	0.5	




Harmonic Analysis


Sample Analysis - 30kva Xfmr, 600 - 120/208, delta-wye, K=1



Measured Values				
Input Line 2				
		Voltage		Current
Frequency	60	RMS	602	26.4
Power		Peak	843	41.9
KW	10.8	DC Offset	-1	-0.2
KVA	15.9	Crest	1.4	1.59
KVAR	11	THD Rms	1.9	24.4
Peak KW	30.5	THD Fund	1.9	25.1
Phase	46° lag	HRMS	12	6.4
Total PF	0.68	KFactor		2.8
DPF	0.7			




Harmonic Values				
Harmonic	Voltage		Current	
	Magnitude	% of fund.	Magnitude	% of fund.
DC	1.0	0.2	0.2	0.8
1	602.0	100.0	25.6	97.0
2	0.0	0.0	0.0	0.0
3	1.0	0.2	1.6	5.9
4	0.0	0.0	0.0	0.1
5	8.0	1.3	5.9	22.3
6	0.0	0.0	0.0	0.1
7	8.0	1.3	1.6	6.0
8	0.0	0.0	0.0	0.1
9	1.0	0.1	0.4	1.7
10	0.0	0.0	0.0	0.1
11	2.0	0.3	1.0	3.9
12	0.0	0.0	0.0	0.1
13	2.0	0.3	0.3	1.3
14	0.0	0.0	0.0	0.1
15	1.0	0.1	0.2	0.7
16	0.0	0.0	0.0	0.0
17	1.0	0.2	0.4	1.4
18	0.0	0.0	0.0	0.0
19	1.0	0.1	0.2	0.7
20	0.0	0.0	0.0	0.0
21	0.0	0.0	0.1	0.5
22	0.0	0.0	0.0	0.0
23	1.0	0.1	0.2	0.8
24	0.0	0.0	0.0	0.0
25	0.0	0.0	0.1	0.3
26	0.0	0.0	0.0	0.0
27	0.0	0.0	0.1	0.4
28	0.0	0.0	0.0	0.1
29	0.0	0.0	0.1	0.5
30	0.0	0.0	0.0	0.0
31	0.0	0.0	0.0	0.1




Harmonic Analysis


Sample Analysis - 30kva Xfmr, 600 - 120/208, delta-wye, K=1



Measured Values				
Input Line 3				
		Voltage		Current
Frequency	60	RMS	604	26.7
Power		Peak	847	41.7
KW	12.3	DC Offset	-2	-0.3
KVA	16.2	Crest	1.4	1.56
KVAR	9.9	THD Rms	2.2	21.7
Peak KW	35	THD Fund	2.2	22.2
Phase	39° lag	HRMS	14	5.8
Total PF	0.76	KFactor		2.6
DPF	0.78			



Harmonic Values				
Harmonic	Voltage		Current	
	Magnitude	% of fund.	Magnitude	% of fund.
DC	2.0	0.2	0.3	1.0
1	604.0	100.0	26.1	97.6
2	0.0	0.1	0.1	0.2
3	1.0	0.2	0.9	3.4
4	0.0	0.0	0.0	0.1
5	9.0	1.5	5.2	19.5
6	0.0	0.0	0.0	0.1
7	9.0	1.5	2.0	7.5
8	0.0	0.0	0.0	0.1
9	1.0	0.2	0.3	1.1
10	0.0	0.0	0.0	0.1
11	2.0	0.4	0.8	3.0
12	0.0	0.0	0.0	0.1
13	2.0	0.3	0.6	2.1
14	0.0	0.0	0.0	0.1
15	1.0	0.1	0.2	0.7
16	0.0	0.0	0.0	0.1
17	1.0	0.2	0.2	0.8
18	0.0	0.0	0.0	0.1
19	1.0	0.2	0.4	1.3
20	0.0	0.0	0.0	0.1
21	0.0	0.1	0.2	0.6
22	0.0	0.0	0.0	0.1
23	0.0	0.1	0.1	0.4
24	0.0	0.0	0.0	0.1
25	1.0	0.1	0.2	0.8
26	0.0	0.0	0.0	0.1
27	0.0	0.1	0.1	0.4
28	0.0	0.0	0.0	0.2
29	0.0	0.0	0.1	0.2
30	0.0	0.0	0.0	0.0
31	0.0	0.0	0.2	0.6



Transformer Derating Estimate

Sample Analysis - 30kva Xfmr, 600 - 120/208, delta-wye, K=1

This derating estimate is based on the highest recorded K-factor value of the input phases

Harmonic	hz	V Mag	%V RMS	V Ø°	I Mag	%I RMS	I Ø°	kW
DC	0	0.4	0.3	0	0.2	0.3	0	0
1	60	118.4	99.9	0	59.7	84.6	-11	6.9
2	119.9	0	0	-171	0	0	-114	0
3	179.9	2.5	2.1	38	32.1	45.5	152	0
4	239.8	0	0	82	0	0	68	0
5	299.8	3.6	3.1	-137	17.8	25.1	-57	0
6	359.8	0	0	32	0	0	-4	0
7	419.7	2.7	2.3	-6	6	8.5	68	0
8	479.7	0	0	-180	0	0	-115	0
9	539.7	1.1	0.9	62	4	5.6	155	0
10	599.6	0	0	0	0	0	-76	0
11	659.6	1.3	1.1	-173	3	4.2	-91	0
12	719.5	0	0	-109	0	0	-45	0
13	779.5	0.9	0.7	-60	1.9	2.7	6	0
14	839.5	0	0	-174	0	0	-59	0
15	899.4	0.8	0.7	22	1.8	2.5	114	0
16	959.4	0	0	129	0	0	-143	0
17	1019.3	0.6	0.5	145	1	1.5	-143	0
18	1079.3	0	0	0	0	0	87	0
19	1139.3	0.7	0.6	-131	1.1	1.6	-51	0
20	1199.2	0	0	-67	0	0	148	0
21	1259.2	0.6	0.5	-30	1	1.4	60	0
22	1319.2	0	0	-173	0	0	124	0
23	1379.1	0.4	0.3	70	0.6	0.9	148	0
24	1439.1	0	0	87	0	0	89	0
25	1499	0.6	0.5	170	0.8	1.1	-106	0
26	1559	0	0	-94	0	0	106	0
27	1619	0.4	0.4	-105	0.6	0.8	-13	0
28	1678.9	0	0	53	0	0	62	0
29	1738.9	0.4	0.3	-15	0.5	0.7	74	0
30	1798.8	0	0	78	0	0	84	0
31	1858.8	0.4	0.3	95	0.5	0.7	-174	0

H	I %Fund.	I ²	I ² H ²	
1	1.0000	1.0000	1.0000	K-Factor 5.8 Derating 0.86 The transformer in this study has a rated capacity of 30 kva Based on the worst case recorded K-factor of: 5.8 this transformer should not be loaded to more than: 86% * of its nameplate rated capacity. It is recommended that the total load on this transformer should be limited to: 25.8 kva The existing load is estimated to be: 26.4 kva
3	0.5377	0.2891	2.6020	
5	0.2982	0.0889	2.2224	
7	0.1005	0.0101	0.4949	
9	0.0670	0.0045	0.3636	
11	0.0503	0.0025	0.3055	
13	0.0318	0.0010	0.1712	
15	0.0302	0.0009	0.2045	
17	0.0168	0.0003	0.0811	
19	0.0184	0.0003	0.1226	
21	0.0168	0.0003	0.1237	
23	0.0101	0.0001	0.0534	
25	0.0134	0.0002	0.1122	
27	0.0101	0.0001	0.0736	
29	0.0084	0.0001	0.0590	
31	0.0084	0.0001	0.0674	

Total 1.3985 8.0573

*Based on 8% eddy current loss (typ. 3-8% for Dry Xfmr<1Mva).